

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7272-1645:137

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: ADEMCO, DBA Honeywell International Inc.,
2 Corporate Center Drive, Ste 100, Melville, New York 11747
Contact: David Kalmus (516) 921-6704 Ext 1910 Fax (516) 364-6953

DESIGN: Models 4192SDM and 4192SDTM photoelectric type smoke detector. Model 4192SDTM employs a supplemental integral 135°F heat sensor. Refer to listee's printed data sheet for additional detailed product description and operational considerations.

RATING: 7-11 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector for use with separately compatible listed fire alarm control units.

NOTE: Formerly 7272-0078:188

01-19-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 12, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division

